



40 years ago

10 forward

John R. Kasich, Lt.
Mary Taylor, Lt. Governor
Scott J. Petty, Director

February 14, 2013

Seth Bromberg
TNT Powerwash, Inc.
708 Internet Drive
Columbus, OH 43207

**Re: Centerpoint - TNT Facility, Franklin County
Construction General Permit #4GC03879*AG**

Dear Mr. Bromberg:

This letter is written regarding the storm water inspection that I conducted on February 11, 2013, at your construction site located at 3220 Toy Road, in Obetz, Ohio. I understand that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the General Storm Water Permit, the following items must be addressed.

Sediment and Erosion Controls:

- It appears that construction is complete and the site is at final grade. Perimeter erosion controls such as silt fence needs to be installed and maintained at the site. A few sections of silt fence were installed at the site, but most of the silt fence was in need of repair. Please install and maintain filter covers on storm water drains. Please see attached pictures.
- Please be aware the General Permit mandates specific permanent and temporary stabilization requirements. All disturbed areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. All areas of final grade must be protected within seven days. All earth disturbing activities should be clearly logged in your inspection reports to ensure the 21 day / seven day requirement is not violated. Given the time of year, alternate erosion control measures such as erosion control matting, crimped mulching, mulch with netting and/or tackifier, or an approvable alternative must be implemented for this site to ensure effective erosion control during the winter months. Please see attached pictures.
- The General Permit requires the permittee to conduct inspections of all sediment and erosion controls every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches. A log of the inspections at the site did not appear to be up-to-date.

Seth Bromberg
TNT Powerwash, Inc.
Page 2

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

A handwritten signature in black ink, appearing to read "G.L. Sanders". The signature is fluid and cursive, with the first letters of the first and last names being capitalized and prominent.

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

ec: Greg Sanders DSW/CDO

GS/nsm Centerpoint-TNT Facility, August 21, 2012



Campanella - NY Facility

Map 1000



