



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

February 19, 2013

Re: Belmont County
 Bethesda WWTP
 Notice of Violation
 Ohio EPA Permit OPB00001*GD
 Correspondence (PWW)

Mayor and Council
 Village of Bethesda
 P.O. Box 36
 Bethesda, Ohio 43719

Dear Mayor and Council Members:

We have received your self-monitoring reports covering the months of January through November 2012 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Outfall	Parameter	Limit Type*	Limit	Reported Value	Violation Date
September 2012	001	Total Suspended Solids	30D Conc	12.0	16.25	9/1/2012
September 2012	001	Total Suspended Solids	7D Conc	18.0	52.5	9/22/2012
September 2012	001	Total Suspended Solids	7D Qty	21.0	24.7084	9/22/2012
November 2012	001	Oil and Grease, Total	1D Conc	10.0	37.8	11/12/2012

Frequency Violation:

Reporting Period	Station	Parameter	Sample Frequency	Expected	Reported	Violation Date
May 2012	001	Fecal Coliform	2/Week	2	1	5/22/2012

- *NOTES: 1D Conc = Daily Average Concentration Value
 1D Qty = Daily Average Loading Value
 7D Conc = Weekly Average Concentration Value
 30D Conc = Monthly Average Concentration Value
 7D Qty = Weekly Average Loading Value
 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Inform this office, in writing, within ten days of receipt of this notification, as to the reasons for the above-referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5416 or nick.hammer@epa.ohio.gov.

Sincerely,

A handwritten signature in blue ink, appearing to read "Nicholas G. Hammer".

Nicholas G. Hammer
Environmental Specialist
Division of Surface Water

NH/dh

- c: Jeremy Campbell, Village of Bethesda
- c: John, Bates, TCCI Laboratories, Inc.