



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

February 19, 2013

**Re:** Belmont County  
Yorkville STP  
Self-monitoring Report Violations  
NPDES Permit 0PB00052\*FD  
Correspondence (PWW)

Mayor and Village Council  
Village of Yorkville  
139 Market Street  
Yorkville, Ohio 43971

Dear Mayor and Council Members:

We have received your self-monitoring reports covering the months of January through November 2012 for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instance of noncompliance and/or deficiency are as follows:

Reporting Period	Outfall	Parameter	Limit Type*	Limit	Reported Value	Violation Date
April 2012	001	pH	1D Conc	6.5	5.91	4/30/2012


\*NOTES: 1D Conc = Daily Average Concentration Value  
1D Qty = Daily Average Loading Value  
7D Conc = Weekly Average Concentration Value  
30D Conc = Monthly Average Concentration Value  
7D Qty = Weekly Average Loading Value  
30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of the receipt of this notification, as to the reasons for the above-referenced violation, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If you have any questions, please contact me at (740) 380-5416 or [nick.hammer@epa.ohio.gov](mailto:nick.hammer@epa.ohio.gov).

Sincerely,

A handwritten signature in blue ink, appearing to read "Nicholas G. Hammer".

Nicholas G. Hammer  
Environmental Specialist  
Division of Surface Water

NH/dh

c: Chad Buksa, Operator