



**Environmental
Protection Agency**

John Kasich Governor
Mary Taylor Lt. Governor
Tony L. White Director

September 19, 2012

Numan Babieh
DOT District 5
9600 Jacksontown Road
Jacksontown, OH 43030

**Re: Storm Water Inspection at LIC-158-0.58 (PID84700) / Licking County
Permit #4GC03667*AG**

Dear Mr. Babieh

This letter is written regarding the storm water inspection I conducted at LIC-158-0.58 (PID84700) on September 13, 2012. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

- There are significant areas on the northern portion of the project appear to be approaching final grade. Please be aware that the General Permit requires erosion protection within seven days following final grade. In addition all idle and barren areas must be protected from erosion in preparation for the upcoming winter months.
- The perimeter controls appear to be maintained except for minor maintenance on the northeast quadrant of the project. Please continue to ensure appropriate maintenance of all controls via your required self-inspections every 7 days or within 24 hours of a precipitation event greater than or equal to half an inch.
- I am pleased with the maintenance and installation of the centralized sediment basins associated with this project. I recognize and appreciate the effort ODOT has demonstrated to implement these basins to minimize off site sedimentation and encourage the use of similar basins on future projects.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm LIC 158 0 58 9-13-2012

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov