



**Environmental
Protection Agency**

Paul R. Raab, Governor
Mike DeWine, Lt. Governor
Harry Kallipolitis, Director

September 19, 2012

Elan Daniel
Rockford Construction Company
999 Polaris Parkway
Columbus, OH 43240

**Re: General Storm Water Permit Investigation at North Fourth East Eighth
Franklin County, Permit #4GC03786*AG**

Dear Mr. Daniel:

This letter is written regarding the storm water inspection I conducted at North Fourth East Eighth on September 13, 2012. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

- During the investigation I noted the use of primarily straw wattles as the sediment control for this site. Please note that I have received complaints regarding the lack of appropriate sediment and erosion controls resulting in sediment laden discharge onto the road and neighboring sidewalks. At this time I am recommending that additional controls, in example silt fence, to minimize sediment laden transport.

Winter Months Onset:

- Please be aware measures are expected to ensure all barren areas are properly protected in preparation for the upcoming winter months. In the event earth disturbing activities extend beyond an effective growing season, alternate erosion protection is expected. This would include but not limited to a crimped straw mulch cover. Please submit to my attention the temporary seeding/protection schedule to ensure the erosion protection requirements are not violated.


Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Elan Daniel
Rockford Construction Company
Page 2

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

A handwritten signature in black ink, appearing to read "Harry Kallipolitis". The signature is written in a cursive style with a large initial "H".

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm North Fourth East Eighth 9-13-2012