



**Environmental  
Protection Agency**

Edward J. Lamb, Governor  
Mary DeRose, Lt. Governor  
Gregory L. Sanders, Director

September 19, 2012

Cheryl Jones  
Liberty Elementary School  
2949 Whitlow Drive  
Columbus, OH 43232

**Re: Liberty Elementary School / Franklin County**

Dear Ms. Jones:

This letter is written regarding the storm water inspection that I conducted on September 17, 2012, at Liberty Elementary School, located at 2949 Whitlow Road, in Columbus, Ohio. I understand that these construction activities are covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the General Storm Water Permit, the following items must be addressed:

**Post Construction Requirements:**

It appears that construction for this site is nearly complete. Most of the barren areas have been stabilized. There are a few barren areas that still need to be stabilized. Please be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven days.

The General Permit mandates specific water quality treatment for storm water following the completion of construction. Please be able to demonstrate your post construction requirements per the General Permit will be met. Please submit to my attention the water quality calculations demonstrating compliance. This information can be sent to my attention via a response letter, or to my email at [greg.sanders@epa.state.oh.us](mailto:greg.sanders@epa.state.oh.us).

If you have not already done so, a Notice of Termination (NOT) will be required providing that the post construction requirements have been met. Instructions and forms can be found at <http://epa.ohio.gov/dsw/storm/index.aspx>.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders  
Storm Water Unit  
Division of Surface Water  
Central District Office

ec: Gregory L. Sanders, DSW/CDO

GS/nsm Liberty ES, September 17, 2012

**Central District Office**  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)