



**Environmental
Protection Agency**

11th Floor Governor
Columbus Lt. Governor
Columbus, Ohio Director

September 20, 2012

Chad Shuttleworth
Mid West Fabricating Company
3115 West Fair Avenue
Lancaster, OH 43130

**Re: Mid West Fabricating Company – Rockmill Division / Fairfield County
Industrial Storm Water Permit 4GR00368*EG**

Dear Mr. Shuttleworth:

This letter is written in regard to the storm water inspection that I conducted on September 18, 2012, at Mid-West Fabricating Company – Rockmill Division, located at 3115 West Fair Avenue, in Lancaster, Ohio. The inspection was conducted to determine compliance with your industrial storm water permit. You stated that your company does metal fabrication. The following items were noted during the inspection:

1. Your company had a storm water pollution prevention plan (SWP3), but it was not at your facility. Please send me an electronic copy of your SWP3 to my email address at greg.sanders@epa.state.oh.us. The plan needs to be updated annually or whenever there is a change in staff that administers the plan. Also, the names and phone numbers of the facility contacts should be listed in the plan and throughout the plant. The local fire department should be among the contacts.
2. There was a spill kit at the loading dock.
3. The area around the covered dumpster was free of debris and oil stains. Housekeeping was much better since the last inspection.
4. There were no other items stored outside other than a few pieces of material handling equipment that was clean and well-maintained.
5. Since your facility does not store or handle chemicals or materials outside, you could be eligible for a no exposure certification. Please see the following weblink for more information on a no exposure certification; <http://epa.ohio.gov/dsw/storm/index.aspx>.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

ec: Greg Sanders, DSW/CDO

GS/nm Mid West Fabricating – Rockmill Div, September 18, 2012