



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: **Notice of Violation**  
Erie County  
Riverview Manor Apartments  
Ohio EPA Permit No.2PW00012\*BD

February 22, 2013

Mr. David Shupe, Owner  
Riverview Manor Apartments  
27 South Street  
Berlin Heights, Ohio 43438

Dear Mr. Shupe:


A review of the self-monitoring reports that are submitted under the National Permit Discharge Elimination System (NPDES) permit for the Riverview Manor Apartments wastewater treatment plant (WWTP) shows that this facility is in significant non-compliance (SNC) for Fecal Coliform bacteria at final outfall number 001. I am enclosing a list of violations for this facility for the period of June 1, 2012, through December 31, 2012.

A facility becomes SNC when it exceeds the effluent limit for four or more months in two consecutive quarters or exceeds the effluent limit significantly in any two months in two consecutive quarters. Achieving compliance with Ohio's environmental laws is a primary focus of Ohio EPA in order to reduce risks to public health and welfare.

We would like to work with you to achieve satisfactory progress to bring this facility back into compliance. Within 30 days of the date of this letter, please submit, in writing, the actions that you propose to undertake in order to return your facility into compliance with your NPDES permit. You will also need to provide us a timetable to implement these actions within a reasonable timeframe. These actions and timetable may also be submitted by email to me at [rick.zuzik@epa.ohio.gov](mailto:rick.zuzik@epa.ohio.gov).

If you wish to meet with us to discuss this matter, please contact me at 419-373-3020 within 10 days of receiving this letter in order to set up a meeting.

Sincerely,



Richard A. Zuzik, MSE  
Division of Surface Water

/jlm

Enclosure

pc: Wood Environmental Services  
ec: Tracking

Get New Data								
Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PW00012*BD	September 2012	001	31616	Fecal Coliform	30D Conc	1000	2600.	9/1/2012
2PW00012*BD	September 2012	001	00530	Total Suspended Solids	30D Conc	30	31.	9/1/2012
2PW00012*BD	September 2012	001	31616	Fecal Coliform	1D Conc	2000	2600.	9/18/2012
2PW00012*BD	October 2012	001	31616	Fecal Coliform	30D Conc	1000	4700.	10/1/2012
2PW00012*BD	October 2012	001	31616	Fecal Coliform	1D Conc	2000	4700.	10/10/2012