



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director  
January 25, 2013

RE: STARK COUNTY  
NIMISHILLEN TOWNSHIP  
CARRIAGE HOUSE  
9033 COLUMBUS RD.  
NPDES NO. 3PR00479

Michael Ritchie  
Robert King  
Precision Holdings, LLC  
591 Noel Street  
Louisville, OH 44641

**CERTIFIED MAIL**

Dear Mr. Ritchie:

On January 17, 2013, this writer conducted a Compliance Evaluation Inspection (CEI) of your wastewater treatment plant located at 9033 Columbus Road. Below you will find a summary of visual observations made during the inspection:

- 1) The plant was being properly aerated and the mixed liquor inside the aeration tank exhibited a good chocolate brown color.
- 2) The sludge and skimmer returns were operating.
- 3) The surface sand filters were clean and raked level.
- 4) The contents of the chlorination/dechlorination tank were clear with no discharge.

A review of your electronic Discharge Monitoring Reports (eDMR) covering the period September 2011 thru November 2012 did not indicate any violations of your National Pollutant Discharge Elimination System (NPDES) permit:

You still have not transferred the NPDES permit to your corporation and therefore you have no authorization to discharge from the treatment plant. **This was brought to your attention in our April 5, 2010 and October 17, 2011 letters and needs to be resolved immediately. Additionally, we have no record that you have applied for a renewal of the NPDES Permit, which expires on March 31, 2013. You must submit the permit transfer and the renewal permit no later than February 15, 2013. This is a violation of Ohio Revised Code 6111.04 and 6111.07. Failure to meet this deadline will result in a referral to our central office to seek civil and monetary penalties as allowed under 6111.99.**

Should you have any questions or comments regarding this letter, please feel free to contact this office at (330)963-1136.

Sincerely,

A handwritten signature in black ink that reads "Philip P. Rhodes".

Philip P. Rhodes, P.E.  
Environmental Specialist II  
Division of Surface Water

PR/cs

cc: Todd Ascani, Stark County Health Department

File: Semi-Public/Carriage House

Northeast District Office • 2110 East Aurora Road • Twinsburg, OH 44087-1924  
www.epa.ohio.gov • (330) 963-1200 • (330) 487-0769 (fax)

7012 1010 0002 2260 1106

**U.S. Postal Service™**  
**CERTIFIED MAIL™ RECEIPT**  
*(Domestic Mail Only; No Insurance Coverage Provided)*

For delivery information visit our website at [www.usps.com](http://www.usps.com)

**OFFICIAL USE**

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$

Postmark  
Here

Sent To

Street, Apt. No.,  
or PO Box No.

City, State, ZIP+4

PS Form 3800, August 2006

See Reverse for Instructions

**SENDER: COMPLETE THIS SECTION**

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Michael Ritchie  
Robert King  
Precision Holdings, LLC  
591 Noel Street  
Louisville, OH 44641

2. Article Number

(Transfer from service label)

7012 1010 0802 2260 1106 DSU

PS Form 3811, February 2004

Domestic Return Receipt

1-29-13

102595-02-M-1540

**COMPLETE THIS SECTION ON DELIVERY**

A. Signature

X *Bel King*

Agent

Addressee

B. Received by (Printed Name)

*Bob King*

C. Date of Delivery

*1-30-13*

D. Is delivery address different from item 1?  Yes  
If YES, enter delivery address below:  No

*5991 Noel ST*

3. Service Type

Certified Mail

Express Mail

Registered

Return Receipt for Merchandise

Insured Mail

C.O.D.

4. Restricted Delivery? (Extra Fee)

Yes