



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: **Notice of Violation**
Auglaize County
Uniopolis WWTP
Ohio EPA Permit No.: 2PA00054
US EPA Permit No.: OH0053317

March 5, 2013

Mayor and Council
Village of Uniopolis
P.O. Box 67
Uniopolis, Ohio 45888

Dear Mayor and Council:

We are in receipt of your self-monitoring reports covering the months of July through December 2012 for the above referenced facilities. Our review indicates violations of the conditions of your National Pollutant Discharge Elimination System (NPDES) permit. The specific instances of non-compliance are enclosed on a separate sheet.

Within 10 days of the date of this letter, please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General Conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code (ORC) Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.


The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are

Mayor and Council
March 5, 2013
Page Two

generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. Information about Ohio EPA's Office of Compliance Assistance & Pollution Prevention can be found on Ohio EPA's Website at <http://epa.ohio.gov/ocapp> or by calling (614) 644 – 3469.

If you have any questions, please contact me at (419) 373 – 3022.

Sincerely,


Justin A. Williams
Environmental Specialist II
Division of Surface Water

/jlm

Enclosure

pc: Mr. Douglas Reinhart

ec: Tracking

Get New Data

Violations for Village of Unioipetie WUPD - July - December 2012

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PA00054*JD	July 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.5	7/5/2012
2PA00054*JD	July 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.2	7/12/2012
2PA00054*JD	July 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.6	7/18/2012
2PA00054*JD	July 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	3.7	7/26/2012
2PA00054*JD	August 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.	8/2/2012
2PA00054*JD	August 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	3.9	8/9/2012
2PA00054*JD	August 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.4	8/16/2012
2PA00054*JD	August 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.4	8/23/2012
2PA00054*JD	September 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.6	9/6/2012
2PA00054*JD	September 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.6	9/13/2012
2PA00054*JD	September 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.8	9/20/2012