



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: **Notice of Violation**  
Auglaize County  
Beverly Hills Subdivision  
Forest Lane Subdivision  
K/Z Sewer District  
Sharlon Subdivision  
NPDES Permits

March 5, 2013

Mr. Douglas P. Reinhart  
Auglaize County Engineer  
P.O. Box 59  
Wapakoneta, Ohio 45895

Dear Mr. Reinhart:

We are in receipt of your self-monitoring reports covering the months of July through December 2012 for the above referenced facilities. Our review indicates violations of the conditions of the National Pollutant Discharge Elimination System (NPDES) permits listed above. The specific instances of non-compliance are enclosed on separate sheets. Further review of your self-monitoring reports for Beverly Hills Subdivision and Sharlon Subdivision for the previous six months, ending in December 2012, indicates that you are in significant non-compliance (SNC) with an effluent limitation contained in each NPDES permit. The specific instances of SNC are enclosed on separate sheets.

A facility becomes in SNC when it exceeds the effluent limit for four or more months in two consecutive quarters or exceeds the effluent limit significantly in any two months in two consecutive quarters. Achieving compliance with Ohio's environmental laws is a primary focus of Ohio EPA in order to reduce risks to public health and welfare.

**Within 21 days** of the date of this letter, please submit, in writing, the actions that you propose to undertake in order to return your facility to compliance with your NPDES permit. You will also need to provide a timeline for these actions that does not extend past May 31, 2013. These actions and timetable may also be submitted by email to me at [Justin.Williams@epa.state.oh.us](mailto:Justin.Williams@epa.state.oh.us).


If we do not receive your timely response or if your response does not adequately address the violations enclosed with this letter, the Director of Ohio EPA will likely take an enforcement action against you to bring these facilities into compliance with Ohio law.

Mr. Douglas P. Reinhart  
March 5, 2013  
Page Two

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. Information about Ohio EPA's Office of Compliance Assistance & Pollution Prevention can be found on Ohio EPA's Website at <http://epa.ohio.gov/ocapp> or by calling (614) 644 – 3469.

If you wish to meet with our office to discuss this matter, please contact me at (419) 373 – 3022 **within 10 days** of receiving this letter in order to set up a meeting.

Sincerely,

  
Justin A. Williams  
Environmental Specialist II  
Division of Surface Water

/jlm

Enclosures

ec: Tracking

Get New Data

# Violations for Beverly Hills Subdivision - July - December 2012

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PG00073*GD	July 2012	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	9.78	7/1/2012
2PG00073*GD	July 2012	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.15	.37017	7/1/2012
2PG00073*GD	July 2012	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.0	9.78	7/8/2012
2PG00073*GD	July 2012	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.23	.37017	7/8/2012
2PG00073*GD	September 2012	001	31648	E. coli	30D Conc	126	156.5	9/1/2012
2PG00073*GD	October 2012	001	31648	E. coli	30D Conc	126	159.7	10/1/2012

Get New  
Data

Get Detail  
for Selected  
Permit

## Facilities in Significant Non-Compliance \*\*

Period: Jul-12 Dec-12

County	Permit #	Facility Name	Major	Station Code	Param Code	Parameter Name	Max % Exceed	# Months Signif Exceed (1)**	# Months Exceed (2)**
Auglaize	2PG00073	Beverly Hills Subdiv		1	31648	E. coli	26.7	2	2

### Footnotes

#### for Significant NonCompliance

\*\* Significant non-compliance with effluent limits occurred if one or more pollutants met the following conditions:

1. During 2 or more months, the reported effluent concentration (or computed load) for a parameter exceeded an effluent limit by:
  - a. 40% for Group 1 pollutants **plus Fecal Coliform**
  - b. 20% for Group 2 pollutants **plus pH, Temperature, whole effluent toxicity**
- or --
2. During 4 or more months, the reported concentration (or computed load) exceeded the limit by > 1%.

Note: This method differs from USEPA Significant Non-compliance (SNC) method in the following ways:

- USEPA only evaluates SNC for average limits. In above analyses, maximum and weekly limits were also considered.

Get New Data

Violations for Forest Lane Subdivision - July - December 2012

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PG00105*ED	August 2012	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.5	2.3	8/1/2012

Get New Data

Violations for K/Z Sewer District - July - December 2012

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PW00006*BD	October 2012	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	9.42	10/1/2012
2PW00006*BD	October 2012	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.038	.17827	10/1/2012
2PW00006*BD	October 2012	001	31616	Fecal Coliform	30D Conc	1000	2419.6	10/1/2012
2PW00006*BD	October 2012	001	80082	CBOD 5 day	30D Conc	10.0	18.6	10/1/2012
2PW00006*BD	October 2012	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.5	9.42	10/22/2012
2PW00006*BD	October 2012	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.057	.17827	10/22/2012
2PW00006*BD	October 2012	001	31616	Fecal Coliform	7D Conc	2000	2419.6	10/22/2012
2PW00006*BD	October 2012	001	80082	CBOD 5 day	7D Conc	15.0	18.6	10/22/2012
2PW00006*BD	October 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.9	10/25/2012

Get New Data

Violations for Sharon Subdivision - July - December 2012

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PG00093*GD	October 2012	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.1	6.81	10/1/2012
2PG00093*GD	October 2012	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.2	6.81	10/22/2012
2PG00093*GD	December 2012	001	00530	Total Suspended Solids	30D Conc	12.0	13.	12/1/2012
2PG00093*GD	December 2012	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	8.4	22.3	12/1/2012
2PG00093*GD	December 2012	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.24	.5402	12/1/2012
2PG00093*GD	December 2012	001	80082	CBOD 5 day	30D Conc	10.0	34.32	12/1/2012
2PG00093*GD	December 2012	001	80082	CBOD 5 day	30D Qty	0.28	.83137	12/1/2012
2PG00093*GD	December 2012	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	12.6	22.3	12/15/2012
2PG00093*GD	December 2012	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.36	.5402	12/15/2012
2PG00093*GD	December 2012	001	80082	CBOD 5 day	7D Conc	15.0	34.32	12/15/2012
2PG00093*GD	December 2012	001	80082	CBOD 5 day	7D Qty	0.43	.83137	12/15/2012

Get New  
Data

Get Detail  
for Selected  
Permit

## Facilities in Significant Non-Compliance \*\*

Period: Jul-12 Dec-12

County	Permit #	Facility Name	Major	Station Code	Param Code	Parameter Name	Max % Exceed	# Months Signif Exceed (1)**	# Months Exceed (2)**
Auglaize	2PG00093	Sharlon Subdiv		1	00610	Nitrogen, Ammonia (NH3)	224.3	2	2

### Footnotes

#### for Significant NonCompliance

\*\* Significant non-compliance with effluent limits occurred if one or more pollutants met the following conditions:

1. During 2 or more months, the reported effluent concentration (or computed load) for a parameter exceeded an effluent limit by:
  - a. 40% for Group 1 pollutants **plus Fecal Coliform**
  - b. 20% for Group 2 pollutants **plus pH, Temperature, whole effluent toxicity**-- or --
2. During 4 or more months, the reported concentration (or computed load) exceeded the limit by > 1%.

Note: This method differs from USEPA Significant Non-compliance (SNC) method in the following ways:

- USEPA only evaluates SNC for average limits. In above analyses, maximum and weekly limits were also considered.