



March 6, 2013

Ron Weaver
Weaver Commercial Construction
2148 B Eagle Pass
Wooster, OH 44691

**Re: London Christian Fellowship Church / Madison County
Construction Storm Water Permit #4GC03872*AG**

Dear Mr. Weaver:

This letter is written in follow-up to a construction storm water inspection that I conducted on February 28, 2013, at the London Christian Fellowship Church, located at 215 US 42 NE, in London, Ohio. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls:

A large portion of the site was barren and near or at final grade. Please be aware the General Permit mandates specific permanent and temporary stabilization requirements. All disturbed areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. All areas of final grade must be protected within seven days. All earth disturbing activities should be clearly logged in your inspection reports to ensure the 21 day / seven day requirement is not violated. Given the time of year, alternate erosion control measures such as erosion control matting, crimped mulching, mulch with netting and/or tackifier, or an approvable alternative must be implement for this site to ensure effective erosion control during the winter months.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

ec: Gregory L. Sanders, DSW/CDO

GS/nsm London Christian Fellowship Church, February 28, 2013