



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Lucas County  
Construction Storm Water  
Michele Drive  
Facility ID No. 2GC03225

March 7, 2013

Mr. Douglas Stevens  
City of Toledo  
One Lake Erie Center  
600 Jefferson Center #300  
Toledo, Ohio 43604

Dear Mr. Stevens:

On February 6, 2013, I inspected Michele Drive, Toledo (photos taken). The site operates under the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity.

At the time of inspection, construction appeared to have been completed. The road appeared recently paved. The site had been seeded. Grass was growing, but it appeared that the initial seeding was not successful in the cul de sac and there were several bare areas in the right of way along the length of the road. The bare areas and areas of sparse growth must be reseeded.

A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:


- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Mr. Douglas Stevens  
March 7, 2013  
Page Two

Your project does not currently meet these criteria. Once a uniform perennial vegetative cover (evenly distributed without large bare areas) with a density of at least 70% cover has been established, you may terminate permit coverage. The NOT form and instructions can be found on our website: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact me at 419-373-3009.

Sincerely,



Lynette Hablitzel, P.E.  
Division of Surface Water  
Storm Water Program

/jlm

ec: Patekka Pope Bannister, City of Toledo Division of Environmental Services  
Tracking