



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Lucas County  
Construction Storm Water  
KFC  
Facility ID No. 2GC03238

March 7, 2013

Mr. Ken Hicks  
Diverse Development  
1428 Albon Road  
Holland, Ohio 43528

Dear Mr. Hicks:

On February 6, 2013, I inspected the KFC project located on the south side of Airport Highway, approximately 250 feet west of Byrne Road, Toledo. The purpose of my visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

At the time of the inspection, no earthwork was occurring and no construction equipment was present. When construction does commence, please remember the permit requirements for storm water management during construction and post construction, such as weekly self-inspections and the requirement to apply cover within seven days on bare soil in any areas that will sit idle for more than 21 days. Your sediment controls must be installed within seven days of grubbing and before any grading.

Please send a written reply within 10 days from the date of this letter describing how the post construction storm water management requirements will be met. Your reply should include the type(s) of practices you are implementing and the basis for their design. I have left a couple phones messages for you at 419-297-7070, but have not received a reply. If there is a better phone number at which to reach you, please include that contact information in your reply, as well as the project's current status and start date. If there are any questions, please contact me at 419-373-3009.

Sincerely,

Lynette Hablitzel, P.E.  
Division of Surface Water  
Storm Water Program

/jlm

cc: Patekka Pope Bannister, City of Toledo Division of Environmental Services  
Tracking