



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: **Notice of Violation**  
Allen County  
Buckeye Pipeline Company -  
Lima Transfer Station &  
South Terminal

March 11, 2013

Ms. Kim Trostel  
HSSE Compliance Specialist  
Buckeye Pipe Line Company  
940 Buckeye Road  
Lima, Ohio 45804

Dear Ms. Trostel:

We are in receipt of your self-monitoring report covering the months of July through December 2012 for the referenced facility. Our review indicates violations of the conditions of the above referenced National Pollutant Discharge Elimination System (NPDES) permits. The specific instances of non-compliance are enclosed on a separate sheet. We have received your email responses dated October 3, 2012, October 19, 2012, and January 16, 2013, and require no further information for the violations at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General Conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code (ORC) Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. Information about Ohio EPA's Office of Compliance Assistance & Pollution Prevention can be found on Ohio EPA's Website at <http://epa.ohio.gov/ocapp> or by calling (614) 644 – 3469.

If there are any questions, please contact me at (419) 373 – 3022.

Sincerely,

Justin A. Williams  
Environmental Specialist II  
Division of Surface Water

/jlm  
Enclosures  
ec: NOV Tracking

Get New Data

Violations for Buckeye Pipe Line Company - L.P. Lima Station July-December 2012

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
21100013*ED	September 2012	001	00400	pH	1D Conc	9.0	9.1	9/25/2012

Get New Data

Buckeye Terminals - Lima South Terminal - July - December 2012

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2IG00011*JD	August 2012	004	00400	pH	1D Conc	9.0	9.48	8/13/2012
2IG00011*JD	December 2012	002	00400	pH	1D Conc	9.0	9.4	12/27/2012