



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: **Notice of Violation**  
Allen County  
Indian Village MHP  
Ohio EPA Permit No. 2PY00001  
NPDES Permit No. OH0058319

March 11, 2013

Mr. Dean Skillman  
Park Management Specialists Corporation  
216 West Wayne Street  
Maumee, Ohio 43537-2125

Dear Mr. Skillman:

We are in receipt of your self-monitoring reports covering the months of July through December 2012 for the referenced facility. Our review indicates violations of the conditions of your National Pollutant Discharge Elimination System (NPDES) permit. The specific instances of non-compliance are enclosed on a separate sheet. Further review of your self-monitoring reports for the previous six months, ending in December 2012, indicates that you are in significant non-compliance (SNC) with an effluent limitation contained in your NPDES permit. The specific instance of SNC is enclosed on a separate sheet.

**Within 10 days** of the date of this letter, please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.


Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General Conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code (ORC) Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

Mr. Dean Skillman  
March 11, 2013  
Page Two

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. Information about Ohio EPA's Office of Compliance Assistance & Pollution Prevention can be found on Ohio EPA's Website at <http://epa.ohio.gov/ocapp> or by calling (614) 644 – 3469.

If there are any questions, please contact me at (419) 373 – 3022.

Sincerely,



Justin A. Williams  
Environmental Specialist II  
Division of Surface Water

/jlm

Enclosures

ec: NOV Tracking

Get New Data

Violations for Indian Village MHP - July - December 2012

Permit No	Reporting Period	Station	Reporting	Parameter	Limit Type	Limit	Reported	Violation Date
			Code				Value	
2PY00001*FD	November 2012	001	00530	Total Suspended Solids	30D Conc	12	17.3333	11/1/2012
2PY00001*FD	November 2012	001	00530	Total Suspended Solids	30D Qty	1.6	2.45268	11/1/2012
2PY00001*FD	November 2012	001	00530	Total Suspended Solids	1D Conc	18	20.	11/5/2012
2PY00001*FD	November 2012	001	00530	Total Suspended Solids	1D Qty	2.4	2.8009	11/5/2012
2PY00001*FD	November 2012	001	00530	Total Suspended Solids	1D Conc	18	30.	11/26/2012
2PY00001*FD	November 2012	001	00530	Total Suspended Solids	1D Qty	2.4	4.20135	11/26/2012
2PY00001*FD	December 2012	001	00530	Total Suspended Solids	30D Conc	12	29.	12/1/2012
2PY00001*FD	December 2012	001	00530	Total Suspended Solids	30D Qty	1.6	5.22709	12/1/2012
2PY00001*FD	December 2012	001	00530	Total Suspended Solids	1D Conc	18	25.	12/3/2012
2PY00001*FD	December 2012	001	00530	Total Suspended Solids	1D Qty	2.4	3.12263	12/3/2012
2PY00001*FD	December 2012	001	00530	Total Suspended Solids	1D Conc	18	35.	12/10/2012
2PY00001*FD	December 2012	001	00530	Total Suspended Solids	1D Qty	2.4	9.40573	12/10/2012
2PY00001*FD	December 2012	001	00530	Total Suspended Solids	1D Conc	18	26.	12/17/2012
2PY00001*FD	December 2012	001	00530	Total Suspended Solids	1D Conc	18	30.	12/22/2012
2PY00001*FD	December 2012	001	00530	Total Suspended Solids	1D Qty	2.4	6.01815	12/22/2012

Get New Data

Get Detail for Selected Permit

## Facilities in Significant Non-Compliance \*\*

Period: Jul-12 Dec-12

County	Permit #	Facility Name	Major	Station Code	Param Code	Parameter Name	Max % Exceed	# Months Signif Exceed (1)**	# Months Exceed (2)**
Allen	2PY00001	Indian Village MHP		1	00530	Total Suspended Solids	291.9	2	2

### Footnotes

#### for Significant NonCompliance

\*\* Significant non-compliance with effluent limits occurred if one or more pollutants met the following conditions:

1. During 2 or more months, the reported effluent concentration (or computed load) for a parameter exceeded an effluent limit by:
  - a. 40% for Group 1 pollutants **plus Fecal Coliform**
  - b. 20% for Group 2 pollutants **plus pH, Temperature, whole effluent toxicity**-- or --
2. During 4 or more months, the reported concentration (or computed load) exceeded the limit by > 1%.

Note: This method differs from USEPA Significant Non-compliance (SNC) method in the following ways:

- USEPA only evaluates SNC for average limits. In above analyses, maximum and weekly limits were also considered.