



10 years and moving forward

John E. Kasich, Governor
Mary Taylor, Lt. Governor
Scott L. Bevilacqua, Director

March 6, 2013

John Wise or Current Storm Water Manager
Target Corporation
P.O. Box 111
Minneapolis, MN 55440

Re: Target at Reynoldsburg Permit Number 4GC02234*AG

Dear Mr. Wise:

This letter is written in follow up to my site observations of the post construction water quality treatment measures noted at the Target at Reynoldsburg in Reynoldsburg, Ohio on February 25, 2013.

It appears the water quality basin located on the west end of the property is **NOW** functioning as intended. It appears the outlet structure which is designed to discharge a water quality volume associated with a 0.75 inch rain event over a 48 hour period, was properly maintained.

I spoke with your contractor who indicated the basin will be seeded as weather permits.

The outlet structure must be routinely inspected to ensure an appropriate working condition. In the event accumulated water in the basin remains in excess of 48 hours or is discharge prior to a 48 hour period following each significant rain event, it is evident there is a malfunction.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at 614-728-3844 or via email at harry.kallipolitis@epa.state.oh.us.

Sincerely

Harry Kallipolitis
Environmental Specialist
Division of Surface Water
Central District Office

HK/nsm Target At Reynoldsburg 2-25-2013