



**Environmental  
Protection Agency**

John Kasich Governor  
Mike DeWine Lt. Governor  
Scott R. Smith Director

September 4, 2012

Jerry Brems  
20 South Second Street  
Newark, OH 43055

**Re: Storm Water Inspection at Etna Parkway Permit #4GC03129\*AG / Licking  
County**

Dear Mr. Brems:

This letter is written regarding the storm water inspection I conducted at Etna Parkway on August 28, 2012. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. An inspection was requested by Ty Yoho of the Licking County Engineering Department. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

**Sediment and Erosion Controls**

- All disturbed areas and vegetated and appear well maintained on the date of this inspection.

**Remaining Stockpiles**

- It is my understanding that the stockpile located at the Northwest section of Refugee Road and Etna Parkway will be removed. Please install perimeter controls associated with the process until all materials are removed from the project area. All barren areas must be stabilized immediately upon removal of this stockpile.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A follow up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Etna Parkway 8-29-2012

**Central District Office**  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)