



40 years of service... moving forward

James E. Kallipolitis, Director
Robert J. Lee, III, Director for
Public Safety, Director

March 6, 2013

Zach Olsen
Licking Heights Local Schools
6539 Summit Road Southwest
Pataskala Ohio 43062

**Re: Storm water inspection at Licking Heights High School / Licking County
Permit #4GC03938*AG**

Dear Mr. Olsen:

This letter is written regarding the storm water inspection I conducted at Licking Heights High School at 4000 Mink Road in Pataskala, Ohio on February 27, 2013. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

- Vegetation is not established sufficient to control erosion; alternative measures such as a crimped mulch cover are expected within seven days from receipt of this letter.
- Please maintain the silt fence at the eastern perimeter of the site.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

for HK
Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Licking Heights High School 2-7-2013