



John E. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Walk, Director

March 20, 2013

Richard Myer
Franklin County Commissioners
373 South High Street
Columbus, OH 43215

Dear Mr. Myer:

This letter is written in follow up to a construction storm water inspection I conducted at Franklin County Courthouse in Columbus, Ohio on March 19, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

It appeared during the inspection that construction activity has been completed for this site and all disturbed areas becoming established with vegetation. A Notice of Termination will be required provided the following are addressed

- Ensure vegetation is sufficient to control erosion measures by a minimum vegetative density of 70 percent.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.

A Notice of Termination (NOT) must be submitted once the conditions above are addressed. The NOT form and filing instructions can be found at:
<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Franklin County Courthouse 3-19-2013