



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

March 19, 2013

Mr. Greg Dove, President
 Caesar Creek Markets
 7812 McEwen Road
 Dayton, Ohio 45459

RE: Caesar Creek Flea Market WWTP, NPDES Permit No. OH72575/ OEPA Permit No. 1PX0003*CD, Notice of Violation

Dear Mr. Dove:

We have reviewed your electronic Discharge Monitoring Reports covering the months of May 2012 to March 2013 for the above referenced facility. Our review indicates violations of the conditions of your NPDES Permit. The specific instances of noncompliance and/or deficiencies were as follows:

Effluent Limit Violations

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
January 2013	Total Suspended Solids	30D Conc	12	28.	1/1/2013
January 2013	Nitrogen, Ammonia (NH3)	30D Conc	3.0	3.6	1/1/2013
January 2013	CBOD 5 day	30D Conc	10	16.	1/1/2013
January 2013	Total Suspended Solids	1D Conc	18	28.	1/10/2013
January 2013	CBOD 5 day	1D Conc	15	16.	1/10/2013

Frequency Monitoring Violations

Reporting Period	Parameter	Sample Frequency	Expected	Reported	Violation Date
November 2012	Turbidity, Severity	1/Day	1	0	11/9/2012
November 2012	Turbidity, Severity	1/Day	1	0	11/23/2012

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Mr. Greg Dove, President
Caesar Creek Markets
March 19, 2013
Page 2

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6028, or michelle.waller@epa.state.oh.us.

Sincerely,



Michelle Waller
Environmental Specialist II
Division of Surface Water

MW/kb

cc: Greg Ross, Winelco, Inc.