



John E. Kasich, Governor
Betty Taylor, Lt. Governor
Tom J. Fitch, Director

March 25, 2013

Andy Finke
Prologis
7048 Fairfield Business Drive
Fairfield, Ohio 45014

**Re: Construction Storm Water Inspection at Etna Corporate Park
Permit Number 4GC04067*AG**

Dear Mr. Finke:

This letter is written regarding the storm water inspection I conducted of the construction activities associated with Etna Corporate Park, located in Etna, Ohio on March 20, 2013. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed::

1. All disturbed areas must be routed to a basin specifically designed for sediment control. I realize basin were installed during previous phases of this development, however, I am unable to determine at this time the associated drainage areas. I am formally requesting an onsite meeting with you or your contractor to evaluate compliance with the General Permit.
2. Earthen berms, diversions or dikes are necessary to ensure positive drainage to the basins intended for sediment control.

If you have any further questions, please feel free to contact me at our Central District Office at (614) 728-3844.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Etna Corporate Park 3-20-2013