



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 21, 2012

Clint Langley  
Taco Bell of America Inc.  
104 Lisa Court  
McMurry, PA 15317

**Re: Storm Water Inspection at Taco Bell – Grove City / Franklin County  
Permit #: 4GC03860\*AG**

Dear Mr. Langley:

This letter is written in follow-up to a construction storm water inspection by Alicia Rector and Elizabeth Plefa of the Ohio EPA, accompanied by Scott Stevens, at Taco Bell – Grove City located at 2787 London – Groveport Road on July 12, 2012. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

#### **Sediment and Erosion Controls**

- All sediment controls are required prior to earth disturbing activities. During the inspection our staff noted major earth disturbance with no evidence of sediment controls resulting in a direct violation of your permit. All sediment control must be implemented within three days receipt of this letter (See Figure 1).
- The entrance of the site must be stabilized to minimize off site vehicle tracking (See Figure 2).
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days (Also See Figure 2).

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office


HK/nsm Taco Bell Grove City 7-13-2012

**Central District Office**  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)



**Figure 1: South side of site void of silt fence**



**Figure 2: Entrance needs stabilization and barren areas lacking erosion protection**