



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Paulding County
Village of Latty
NPDES Permit

April 2, 2013

Mayor and Council
Village of Latty
P.O. Box 86
Latty, Ohio 45855

Dear Mayor and Council:

On March 20, 2013, I conducted an inspection the wastewater treatment plant (WWTP) serving the Village of Latty. Mr. Tommy Roth of Industrial Fluid Management (IFM), the operator of the WWTP, was present and provided information regarding the plant.

At the time of inspection, both SBR units were in service and the effluent appeared typical. The system controls housed in the building were recently upgraded for better system operation and remote access from the operator's headquarters when the WWTP is not staffed.

Our records indicate that the WWTP discharge was in significant non-compliance with the permit limits for suspended solids, ammonia, and E coli in the fourth quarter of 2012 (spread sheet record enclosed).

Part I, C – Schedule of Compliance of the Village's National Pollutant Discharge Elimination System (NPDES) permit requires the Village to take actions within a given timeline to improve the WWTP and comply with the discharge limits. Our office has not received any correspondence from the Village regarding these actions. Please review this part of the permit and advise this office on this matter no later than April 15, 2013. Satisfactory progress must be made or we will have no choice but to recommend escalated enforcement action.

If you have any questions regarding the above, please contact me at naajy.abdullah@epa.ohio.gov or (419) 373-3017.

Sincerely,


Naajy Abdullah, P.E.
Division of Surface Water

/jlm
Enclosure
pc: Tommy Roth, IFM
ec: Tracking

Get New Data

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PA00073*HD	January 2012	001	00530	Total Suspended Solids	30D Qty	2.73	3.34973	1/1/2012
2PA00073*HD	January 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.27	1/10/2012
2PA00073*HD	June 2012	001	31648	E. coli	7D Conc	2318	2500.	6/15/2012
2PA00073*HD	October 2012	001	00530	Total Suspended Solids	30D Conc	18.0	34.	10/1/2012
2PA00073*HD	October 2012	001	00530	Total Suspended Solids	30D Qty	1.64	3.34594	10/1/2012
2PA00073*HD	October 2012	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	14.1	10/1/2012
2PA00073*HD	October 2012	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.45	1.38758	10/1/2012
2PA00073*HD	October 2012	001	31648	E. coli	30D Conc	1030	7636.	10/1/2012
2PA00073*HD	October 2012	001	00530	Total Suspended Solids	7D Conc	27.0	34.	10/22/2012
2PA00073*HD	October 2012	001	00530	Total Suspended Solids	7D Qty	2.46	3.34594	10/22/2012
2PA00073*HD	October 2012	001	00610	Nitrogen, Ammonia (NH3	7D Conc	7.5	14.1	10/22/2012
2PA00073*HD	October 2012	001	00610	Nitrogen, Ammonia (NH3	7D Qty	0.68	1.38758	10/22/2012
2PA00073*HD	October 2012	001	31648	E. coli	7D Conc	2318	7636.	10/22/2012
2PA00073*HD	December 2012	001	00530	Total Suspended Solids	30D Conc	30.0	47.	12/1/2012
2PA00073*HD	December 2012	001	00530	Total Suspended Solids	7D Conc	45.0	47.	12/15/2012

