



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



March 25, 2013

RE: SUMMIT COUNTY
SPRINGFIELD TWP.
ALEXANDER'S MOBILE HOME PARK
OHIO EPA PERMIT NO. 3PV00129
COMPLIANCE EVALUATION INSPECTION

CERTIFIED MAIL

Mr. Bill Mosholder
DB Development, LLC
10 Northwest Avenue #100
Tallmadge, OH 44278

Dear Mr. Mosholder:

On March 18, 2013, a Compliance Evaluation Inspection (CEI) was conducted at the wastewater treatment plant (WWTP) serving Alexander's Mobile Home Park. The purpose of such an inspection is to determine whether the plant is meeting the requirements of its National Pollutant Discharge Elimination System (NPDES) permit, and to inspect the overall condition of the plant.

According to our files, the existing wastewater treatment system consists of a trash trap and a 7,500 gallon extended aeration tank. It is understood that the plant's effluent runs through a 6" perforated clay pipe laid in crushed rock from where it leaches down to the lower part of the area on the west side of the property.

At the time of the inspection, the plant was running but wasn't the proper color and was quite odorous. The receiving wetland appeared to contain some solids/sludge.

Upon review of the electronic Discharge Monitoring Reports (eDMR's) submitted for the plant from January 2012 through January 2013, the following effluent violations were noted:

Please be advised that such instances of noncompliance are subject to enforcement pursuant to Ohio Revised Code (ORC) 6111.

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
March 2012	Total Suspended Solids	30D Conc	12	34.	3/1/2012
March 2012	Total Suspended Solids	30D Qty	0.34	.47615	3/1/2012
March 2012	Nitrogen, Ammonia (NH3)	30D Conc	3.0	33.2	3/1/2012
March 2012	Nitrogen, Ammonia (NH3)	30D Qty	0.09	.46495	3/1/2012
March 2012	CBOD 5 day	30D Conc	10	18.	3/1/2012
March 2012	Total Suspended Solids	7D Conc	18	34.	3/15/2012
March 2012	Nitrogen, Ammonia (NH3)	7D Conc	4.5	33.2	3/15/2012
March 2012	Nitrogen, Ammonia (NH3)	7D Qty	0.13	.46495	3/15/2012
March 2012	CBOD 5 day	7D Conc	15	18.	3/15/2012


ALEXANDER'S MOBILE HOME PARK
MARCH 25, 2013
PAGE 2 OF 2

June 2012	Nitrogen, Ammonia (NH3)	30D Conc	1.0	63.	6/1/2012
June 2012	Nitrogen, Ammonia (NH3)	30D Qty	0.03	.73921	6/1/2012
June 2012	Nitrogen, Ammonia (NH3)	7D Conc	1.5	63.	6/8/2012
June 2012	Nitrogen, Ammonia (NH3)	7D Qty	0.04	.73921	6/8/2012
August 2012	Nitrogen, Ammonia (NH3)	30D Conc	1.0	30.7	8/1/2012
August 2012	Nitrogen, Ammonia (NH3)	30D Qty	0.03	.39275	8/1/2012
August 2012	Nitrogen, Ammonia (NH3)	7D Conc	1.5	30.7	8/8/2012
August 2012	Nitrogen, Ammonia (NH3)	7D Qty	0.04	.39275	8/8/2012
December 2012	CBOD 5 day	30D Conc	10	14.	12/1/2012
December 2012	Total Suspended Solids	30D Conc	12	20.	12/1/2012
December 2012	Nitrogen, Ammonia (NH3)	30D Conc	3.0	59.8	12/1/2012
December 2012	Nitrogen, Ammonia (NH3)	30D Qty	0.09	.71479	12/1/2012
December 2012	Total Suspended Solids	7D Conc	18	20.	12/8/2012
December 2012	Nitrogen, Ammonia (NH3)	7D Conc	4.5	59.8	12/8/2012
December 2012	Nitrogen, Ammonia (NH3)	7D Qty	0.13	.71479	12/8/2012

As you know, you are in non-compliance with the timeframes set forth in your NPDES permit's Compliance Schedule. Abandonment of your treatment plant and construction of the sanitary sewer connection was to be completed within five months of the effective date of your permit. However, this office has been receiving periodic updates from you concerning progress being made towards construction of a force main connection to Akron's existing sewer line southeast of the park. This office expects construction to be completed this Spring of 2013.

In conclusion, although the existing WWTP does not meet our current standards and is having a many effluent violations, this office is willing to hold off on additional enforcement actions because of the upcoming sewer connection project. Please continue to update this office weekly. If you have any questions concerning this letter, please contact me at (330) 963-1151.

Sincerely,



Jennifer S. Bennage
Environmental Engineer
Division of Surface Water

JSB/cs

ec: Brent Paulus, Summit County Health Dept.
Bob Hasenyager, Summit County H.D.
Ronald Lambert, Plant Operator

cc: Deborah Davis, Springfield Township Trustee
Pat Gsellman, City of Akron
Don Gallimore, Summit County D.O.E.S.

U.S. Postal Service™
CERTIFIED MAIL™ RECEIPT
(Domestic Mail Only; No Insurance Coverage Provided)

For delivery information visit our website at www.usps.com

OFFICIAL USE

7012 1010 0002 2260 1281

Postage	\$	Postmark Here
Certified Fee		
Return Receipt Fee (Endorsement Required)		
Restricted Delivery Fee (Endorsement Required)		
Total Postage & Fees	\$	

Sent To

Street, Apt. No.,
or PO Box No.

City, State, ZIP+4

PS Form 3800, August 2006 See Reverse for Instructions

SENDER: COMPLETE THIS SECTION	COMPLETE THIS SECTION ON DELIVERY
<ul style="list-style-type: none"> Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired. Print your name and address on the reverse so that we can return the card to you. Attach this card to the back of the mailpiece, or on the front if space permits. 	<p>A. Signature: <u>Erin Bicker</u> <input type="checkbox"/> Agent <input type="checkbox"/> Addressee</p> <p>B. Received by (Printed Name): <u>Erin Bicker</u></p> <p>C. Date of Delivery: <u>3-26-13</u></p> <p>D. Is delivery address different from item 1? <input type="checkbox"/> Yes If YES, enter delivery address below: <input type="checkbox"/> No</p>
<p>1. Article Addressed to:</p> <p>Mr. Bill Mosholder DB Development, LLC 10 Northwest Avenue #100 Tallmadge, OH 44278</p>	<p>3. Service Type</p> <p><input checked="" type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail</p> <p><input type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise</p> <p><input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D.</p>
<p>2. Article Number (Transfer from service label) <u>7012 1010 0002 2260 1281</u></p>	<p>4. Restricted Delivery? (Extra Fee) <input type="checkbox"/> Yes</p>

3-25-13

