



on R. Kasich, Governor
John Kasich, Lt. Governor
John Kasich, Director

April 11, 2013

David Mohr
Ohio Department of Natural Resources
2045 Morse Road, Building E-3
Columbus, Ohio 43229

Re: Construction Storm Water Inspection at South Fork of the Licking River in Licking County: Permit Number: 4GC03824*AG

Dear Mr. Mohr:

This letter is written regarding a storm water inspection I conducted at the South Fork of the Licking River Improvements in Licking County on April 4, 2013. Ohio EPA has received and approved this site for coverage under the General Storm Water Permit associated with Construction Activities. During the inspection, I noted the following

Site Observations

- During the inspection I evaluated the operations east of State Route 79. I spoke with the onsite contractor for the site and evaluated the berms along the South Fork of the Licking River. These berms serve as a primary sediment control for the site and were maintained in a satisfactory manner. Please continue to maintain the berms during all phases of construction.
- I noted that construction activities have commenced west of State Route 79. Please ensure the berm is maintained at all times, until such time vegetation is established sufficient to control erosion.
- Please be aware the General Permit mandates specific permanent and temporary stabilization requirements. All disturbed areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. All areas of final grade must be protected within seven days. All earth disturbing activities should be clearly logged in your inspection reports to ensure the 21 day / seven day requirement is not violated.

- Please be aware the contractor must sign-on as a co-permittee for the site as required by the General Permit. The co-permittee form can be found at the following address: http://www.epa.ohio.gov/portals/35/storm/NOI_co-1_fis.pdf. The instructions can be found at the following address: http://www.epa.ohio.gov/portals/35/storm/co-perm_noi_inst_s.pdf.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office