



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

April 5, 2013

RE: TRUMBULL COUNTY
CALVARY BIBLE CHURCH
NPDES PERMIT NO. OHC000003
OHIO EPA PERMIT NO. 3GC05861*AG
CONSTRUCTION STORM WATER INSPECTION

NOTICE OF VIOLATION

CERTIFIED MAIL

Jeff Rice
Calvary Bible Church
4511 Mahoning Avenue
Warren, OH 44483

Dear Mr. Rice:

On March 11, 2013, Ohio EPA conducted a storm water inspection at Calvary Bible Church, located at the southeast intersection of State Route 305 and Hoagland Blackstub Road, Bazetta Township, Trumbull County (site). Marcus Hollenbank of the Trumbull County Soil and Water Conservation District (Trumbull SWCD) accompanied the undersigned. Ohio EPA records indicate that the site is covered by General National Pollutant Discharge Elimination System (NPDES) Permit for Storm Water Associated with Industrial Activity (General Storm Water Permit), permit No. 3GC05861*AG. The inspection documented the following violations:

Storm Water Inspection

- Construction activities have commenced on the site (i.e. extensive grading activities, installation of the onsite sanitary treatment system, roadway construction, etc.) and no approvable erosion and sediment best management practices (BMP) have been installed to prevent the discharge of sediment to "waters of the State." Diversion channels have been constructed with straw bails installed along the roadway to direct untreated sediment-laden storm water runoff to discharge to "waters of the State." Straw bails are not an approvable BMP to prevent the treat sediment-laden storm water runoff.

The failure to install appropriate erosion and sediment controls constitute violations of Ohio Revised Code, Chapter (ORC) 6111.07 and Part III.G.2.c of the General Storm Water Permit.

The failure to implement the site's storm water pollution prevention plan (SWP3) upon initiation of construction activities constitutes violations of ORC 6111.07 and Part III.B of the General Storm Water Permit.

Storm Water Pollution Prevention Plan

- In accordance with Part II.C.2 of the General Storm Water Permit, Ohio EPA requests a copy of the site's SWP3 to be submitted for review within ten days of receiving this notice of violation. In addition, the SWP3 must include information detailing how Part III.G.2.e of the General Storm Water Permit will be satisfied.

Corrective Action

The following information must be immediately submitted to Ohio EPA for review:

- A copy of the site's SWP3;
- Information must be submitted that details the design of post-construction BMPs and includes all necessary calculations (i.e. dewatering time, drainage areas, sizing calculations, etc.);
- Copies of all the inspection reports for the period consisting of November 1, 2012 to April 1, 2013; and
- A report detailing the corrective action(s) that will be or have been implemented to address all of the violations detailed above. The report must include dates when each corrective action(s) has been or will be implemented and completed.

Ohio EPA previously requested the above information to be submitted within ten days of receiving the January 18, 2013 Notice of Violation. **The failure to provide a copy of the requested information constitute violations of ORC 6111.07, Part III.C.2.b of the General Storm Water Permit, and Part V.E of the General Storm Water Permit.**

Failure to resolve the above violations will result in Ohio EPA pursuing formal enforcement, whereby violations of ORC Chapter 6111 are punishable by fines up to \$10,000 a day per violation. Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1118 or via e-mail at chris.moody@epa.ohio.gov.

Sincerely,



Chris Moody
Environmental Specialist II
Division of Surface Water

CM/cs

ec: Mike Wilson, Trumbull SWCD
Marcus Hollenbank, Trumbull SWCD

U.S. Postal Service™
CERTIFIED MAIL™ RECEIPT
(Domestic Mail Only; No Insurance Coverage Provided)

For delivery information visit our website at www.usps.com

OFFICIAL USE

7012 1010 0002 2260 1335

Postage	\$	Postmark Here
Certified Fee		
Return Receipt Fee (Endorsement Required)		
Restricted Delivery Fee (Endorsement Required)		
Total Postage & Fees	\$	

Sent To

Street, Apt. No.,
or PO Box No.

City, State, ZIP+4

PS Form 3800, August 2006 See Reverse for Instructions

SENDER: COMPLETE THIS SECTION	COMPLETE THIS SECTION ON DELIVERY
<ul style="list-style-type: none"> Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired. Print your name and address on the reverse so that we can return the card to you. Attach this card to the back of the mailpiece, or on the front if space permits. 	<p>A. Signature <input checked="" type="checkbox"/> Agent <input type="checkbox"/> Addressee</p> <p>B. Received by (Printed Name) DANIEL H WEBER</p> <p>C. Date of Delivery 4-10-13</p> <p>D. Is delivery address different from item 1? <input type="checkbox"/> Yes If YES, enter delivery address below: <input type="checkbox"/> No</p>
<p>1. Article Addressed to:</p> <p>Jeff Rice Calvary Bible Church 4511 Mahoning Avenue Warren, OH 44483</p>	<p>3. Service-Type</p> <p><input checked="" type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail <input type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise <input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D.</p>
<p>2. Article Number (Transfer from service label) 7012 1010 0002 2260 1335</p>	<p>4. Restricted Delivery? (Extra Fee) <input type="checkbox"/> Yes</p>

