



John R. Kasich, Governor
Betty Taylor, Lt. Governor
Scott R. Gally, Director

April 11, 2013

Eric Leu
AEP
1 Riverside Plaza
Columbus, Ohio 43215

Re: Storm Water Inspection at Blair Station, Permit Number 4GC03791*AG

Dear Mr. Leu:

This letter is written in follow up to storm water inspection I conducted at Blair Station on April 1, 2013 of the construction activities associated with the site. This site is currently covered under Ohio EPA, General Storm Water Permit. The following observations were made:

Site Observations:

- Perimeter areas maintained.
- The concrete wash out area was maintained as requested
- Please ensure positive drainage to the impoundment intended for sediment control.
- Please ensure monitoring of the sediment basin in compliance with the conditions of your Storm Water Pollution Prevention Plan.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Blair Station 4-1-2013