



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

April 16, 2013

Chasity Dingess
Joshua Homes
76 Stoney Bluff Way
Lithopolis, OH 43136

Re: Stoney Bluff Subdivision / Fairfield County

Dear Ms. Dingess:

This letter is written in follow-up to a construction storm water inspection that I conducted on April 18, 2013, at Stoney Bluff Subdivision, located in Lithopolis, Ohio. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. There was no active construction at the site during my inspection. During the inspection, I noted the following:

Sediment and Erosion Controls

- There was one barren lot that needs to be stabilized.
- The storm water pond needs to have a riser installed on the discharge outlet of the pond.
- Any lots that have been sold, need to have an individual lot notice of intent (NOI). The NOI application form must be submitted to the Agency. This application may be obtained at the following weblink:
<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

ec: Greg Sanders, DSW/CDO

GS/nm Stoney Bluff Subdivision, March 27, 2013