



John D. Kasich, Governor
Paul Taylor, Lt. Governor
Scott J. Kelly, Director

April 16, 2013

Lisa Dobberstein
DiYanni Homes
1537 Brice Road
Reynoldsburg, OH 43068

Re: Rolling Acres / Fairfield County

Dear Ms. Dobberstein:

This letter is written regarding the storm water inspection that I conducted on March 27, 2013, at Rolling Acres, located along Elder Road, in the Village of Lithopolis, Ohio. I understand that these construction activities are covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

During the inspection, I noted that there were three homes under construction and one barren stockpile at the site. Two active sites needed to extend the erosion controls to better capture the erosion and the third site (DiYanni) needed to install erosion controls. Please see attached pictures.

Please be aware the General Permit mandates specific permanent and temporary stabilization requirements. All disturbed areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. All areas of final grade must be protected within seven days. All earth disturbing activities should be clearly logged in your inspection reports to ensure the 21 day / seven day requirement is not violated.

The General Permit requires the permittee to conduct inspections of all sediment and erosion controls every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches. A log of the inspections and resulting corrective actions must be maintained on site available for review. All earth disturbing activities must be clearly documented in your inspection reports to ensure the temporary or permanent stabilization requirements are not violated.

Wayne Homes must have a lot notice of intent. Any contractors that are in responsible charge of the erosion controls must have a co-permittee application.

Lisa Dobberstein
DiYanni Homes
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

A handwritten signature in cursive script, appearing to read 'G. Sanders', written in black ink.

Gregory L. Sanders
Storm Water Unit
Division of Surface Water
Central District Office

cc: Wayne Homes, Sunbury, OH

ec: Greg Sanders, DSW/CDO

GS/nsm Rolling Acres, March 27, 2013

