



John E. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Mally, Director

April 18, 2013

Franz A. Geiger  
8800 Lyra Drive Suite 550  
Columbus, OH 43240

**Re: Storm Water Inspection at Zumstein South Stream and Wetland Mitigation Project /  
Delaware County / Permit #4GC03539\*AG**

Dear Mr. Geiger:

This letter is written in follow up to a construction storm water inspection I conducted at Zumstein South Stream and Wetland Mitigation Project on April 11, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

**Sediment and Erosion Controls**

- Construction activities recently commenced for the 2013 construction season. Please ensure all perimeter controls are maintained and positive drainage is established to the impoundments intended for sediment control as the winter months have jeopardized the intended function of all controls.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Zumstein South Stream and Wetland Mitigation 4-11-2013