



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

April 26, 2013

Mr. John Green
 Indian Ridge Golf Course
 2600 Oxford - Millville Road
 Oxford, Ohio 45056

**RE: Butler County, Indian Ridge Golf Course
 Land Application Management Plan Violations**

Dear Mr. Green:

We have reviewed your Discharge Monitoring Reports (DMRs) covering the months of October 2012 through March 2013 for the referenced facility. The DMRs are submitted as required by the approved Land Application Management Plan (Ohio EPA Application Number 1MP00013*AM). The specific instances of noncompliance were as follows:

Effluent Limit Violations for October 2012 through March 2013

Reporting Period	Station	Parameter	Limit Type	Units	Permit Limit	Reported Value
October 2012	601	Chlorine	Daily	mg/l	1 (min.)	0.19
October 2012	601	Chlorine	Daily	mg/l	1 (min.)	0.07
November 2012	601	Chlorine	Daily	mg/l	1 (min.)	0.20
November 2012	601	Chlorine	Daily	mg/l	1 (min.)	0.22
December 2012	601	Chlorine	Daily	mg/l	1 (min.)	0.21
February 2013	601	Chlorine	Daily	mg/l	1 (min.)	0.59

Please be advised that failure to comply with the effluent limitations of your Land Application Management Plan may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your reports addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

Finally, the management plan approval requires that the remaining freeboard as

Mr. John Green
Indian Ridge Golf Course
April 26, 2013
Page 2

measured in feet be monitored and reported for the storage pond. This vertical distance is measured from the top of the wastewater to the top of the storage pond. Please ensure that the information report on the DMRs is accurate.

If you have any questions regarding the above, please contact me at (937) 285 - 6096.

Sincerely,

A handwritten signature in cursive script, appearing to read "Ned Sarle".

Ned Sarle
Environmental Specialist
Division of Surface Water
Permit Section

NS/kb

cc: Andy Griner, Winelco, Inc.