



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

April 26, 2013

Ms. Mary Malotke  
Saint Thomas Episcopal Church  
100 Miami Avenue  
Terrace Park, Ohio 45174

**RE: Hamilton County, Saint Thomas Episcopal Church, NPDES Permit Violations**

Dear Ms. Malotke:

We have reviewed your Discharge Monitoring Reports (DMRs) covering the months of September 2012 through March 2013 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0127388; OEPA Permit # 1PR00108\*CD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations for September 2012 through March 2013

Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
March 2013	TSS	Monthly	mg/l	12.0	20
March 2013	Ammonia	Monthly	mg/l	3.0	4.6
March 2013	TSS	Weekly	mg/l	18.0	20

Please be advised that failure to comply with the effluent limitations or to satisfy the reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, by May 10, 2013 as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or

Ms. Mary Malotke  
Saint Thomas Episcopal Church  
April 26, 2013  
Page 2

proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

A handwritten signature in black ink, appearing to read "Ned Sarle".

Ned Sarle  
Environmental Specialist  
Division of Surface Water  
Permit Section

NS/kb

cc: David Leverage, Winelco, Inc.