



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

April 30, 2013

Re: Jackson County
 Jackson WWTP
 Self-Monitoring Report Violations
 Ohio EPA Permit OPD00008*JD
 Correspondence (PWW)

Mayor and Council
 City of Jackson
 145 Broadway Street
 Jackson, Ohio 45640

We have received your self-monitoring report covering the month of March 2013 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Type	Date	Reporting Code	Parameter	Limit Type	Permit Limit	Reported Value
001	Limit	3/1/2013	00530	Total Suspended Solids	Monthly Conc.	10	32.9823
001	Limit	3/1/2013	00530	Total Suspended Solids	Weekly Conc.	15	71.5
001	Limit	3/1/2013	00530	Total Suspended Solids	Monthly Load	143	442.957
001	Limit	3/1/2013	00530	Total Suspended Solids	Weekly Load	215	1152.11
001	Limit	3/8/2013	00530	Total Suspended Solids	Weekly Conc.	15	23.45
001	Limit	3/15/2013	00530	Total Suspended Solids	Weekly Conc.	15	24.775
001	Limit	3/15/2013	00530	Total Suspended Solids	Weekly Load	215	330.701
001	Limit	3/1/2013	00610	Nitrogen, Ammonia (NH3)	Monthly Conc.	3.0	5.515
001	Limit	3/1/2013	00610	Nitrogen, Ammonia (NH3)	Monthly Load	43.0	60.2876
001	Limit	3/8/2013	00610	Nitrogen, Ammonia (NH3)	Weekly Conc.	4.5	5.49667
001	Limit	3/15/2013	00610	Nitrogen, Ammonia (NH3)	Weekly Conc.	4.5	8.902
001	Limit	3/15/2013	00610	Nitrogen, Ammonia (NH3)	Weekly Load	64.6	101.840
001	Limit	3/22/2013	00610	Nitrogen, Ammonia (NH3)	Weekly Conc.	4.5	4.88
001	Limit	3/1/2013	00665	Phosphorus, Total (P)	Monthly Conc.	1.0	1.3724
001	Limit	3/1/2013	00665	Phosphorus, Total (P)	Monthly Load	14.3	16.2220
001	Limit	3/15/2013	00665	Phosphorus, Total (P)	Weekly Conc.	1.5	1.785
001	Limit	3/1/2013	80082	CBOD 5 day	Monthly Conc.	10	35.5882
001	Limit	3/1/2013	80082	CBOD 5 day	Weekly Conc.	15	109.875
001	Limit	3/1/2013	80082	CBOD 5 day	Monthly Load	143	492.158
001	Limit	3/1/2013	80082	CBOD 5 day	Weekly Load	215	1682.35
001	Limit	3/8/2013	80082	CBOD 5 day	Weekly Conc.	15	19.3833


Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets and U.S. EPA's Facility Pollution Prevention Guide, (EPA/600/R-92/088), you may contact the Ohio EPA Pollution Prevention Section at (614) 644-3469 or me for additional information.

If there are any questions, please contact this office.

Sincerely,



Aaron Pennington
District Representative
Division of Surface Water

AP/dh