



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Wyandot County
Concerted Manufacturing of Nevada
NPDES Permit

May 1, 2013

Mr. David Linton
Viands Concerted Inc.
6976 Clark State Road
Blacklick, Ohio 43004-9737

Dear Mr. Linton:

This will acknowledge our April 23, 2013, compliance inspection at your Wyandot facility. This facility is located at 17739 State Route 231, Nevada, Ohio. This inspection was conducted as part of the facility's National Pollutant Discharge Elimination System (NPDES) permit No. 2IH00088 (OH0078212).

At the time of the inspection, Outfall 001 from the wastewater treatment plant (WWTP) was not discharging. This facility was still closed for business and the building remained unoccupied. The last Electronic Discharge Monitoring Report (eDMR) was submitted in June of 2010. Please note that you are required to continue submitting eDMRs to the Agency.

Your facility's NPDES permit expired on February 29, 2012. In order to receive authorization to discharge beyond the expiration date, you shall submit a renewal NPDES permit application to our office as soon as possible, but no later than June 1, 2013.

A copy of our completed inspection report is included for your records. Should you have any questions, please contact me.

Yours truly,


Jason Ko
Division of Surface Water

/jlm

Enclosure

pc: Wyandot County Health Department

ec: Tracking

NPDES COMPLIANCE INSPECTION REPORT

Section A: National Data System Coding

Permit #	NPDES	Yr/Mo/Day	Inspection Type	Inspector	FacType
21H00088	OH0078212	2013/4/23	C	S	2

Section B: Facility Data

Name and Location of Facility Inspected Concerted Manufacturing of Nevada 17739 State Route 231 Nevada, OH 44849	Entry Time 12:30 P.M.	Permit Effective Date 3/1/2007
	Exit Time 12:45 P.M.	Permit Expiration Date 2/29/2012

Name(s) and Title(s) of On-Site Representative(s) Phone Number(s)

Name, Address and Title of Responsible Official Phone Number


David Linton
 Viands Concerted Inc
 (Concerted Manufacturing of Nevada)
 6976 Clark State Road
 Blacklick, OH 43004-9737

Section C: Areas Evaluated During Inspection (S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)


<u>S</u> Permit	-- Flow Measurement	-- Pretreatment
<u>N</u> Records/Reports	-- Laboratory	-- Compliance Schedules
-- Operations & Maintenance	-- Effluent	<u>U</u> Self-Monitoring Program
<u>M</u> Facility Site Review	-- Sludge Storage/Disposal	-- Other

Section D: Summary of Findings/Comments (Attach additional sheets if necessary)

- * Outfall 001 from the 160,000 gpd WWTP did not discharge
- * The manufacturing facility was still closed & building unoccupied
- * The NPDES permit expired on 2/29/2012
- * Submit NPDES renewal application by 6/1/2013
- * Last eDMR submitted to the Agency was in 6/2010; Continue submitting eDMR


 Jason Ko
 Name(s) and Signature(s) of Inspector(s)

4/29/13
 Date, Ohio EPA, Northwest District Office


 Thomas Poffenbarger, P.E.
 Name and Signature of Reviewer

4/26/13
 Date, Ohio EPA, Northwest District Office