



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

May 14, 2013

RE: MAHONING COUNTY
BULK STORAGE FACILITY
STORMWATER
NPDES PERMIT NO. 3I100006
SFY 2013 CEI

Ms. Monica Styles
Environmental Specialist
Sunoco Partners Marketing and Terminals
7155 Inkster Road
Taylor, MI 48180

Ms. Styles:

On April 15, 2013, this writer conducted an unannounced Compliance Evaluation Inspection (CEI) of the bulk petroleum storage facility located at 439 Oak Street, Boardman, OH. The intent of the inspection was to evaluate the site and receiving stream for any impacts resulting from the discharge of stormwater from the bulk storage area. A precipitation event was occurring at the time of the inspection.

The site was considered satisfactory at the time of the inspection. No impacts to the receiving stream resulting from the discharge of storm water were identified. Clear storm water was flowing from the site at the time of the inspection.


A review of the monthly monitoring data for the facility was reviewed as part of this inspection. The period of review was January 2012 through March 2013. Following is a single violation reported during the review period.

Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
March 2013	001	00400	pH	1D Conc	6.5	6.42	3/18/2013

This violation was explained in an April 25, 2013 email from Jennifer Roberts of Sunoco Logistics. It is understood that the violation was caused by the exceedance of the 15 min. hold time for pH analysis. It is understood that the facility has purchased a new pH meter so all pH readings can be recorded in the field.

You may contact this office at (330) 963-1251 or at john.kwolek@epa.state.oh.us to discuss any questions you may have.

Respectfully,


John Kwolek
District Engineer
Division of Surface Water

JK/cs