



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

May 16, 2013

RE: INLAND CORP -- MOGADORE
PERMIT NO. 3IG0000*FD
PORTAGE COUNTY

Tom Mellert
Inland Corporation
257 Saxe Road
Mogadore, Ohio 44260

Dear Mr. Mellert:

On April 24, 2013, this writer conducted a compliance evaluation inspection of your facility referenced above. Mr. Dan Ray, represented your company during the inspection. Below is a summary of the inspection:

Inland Corporation-Mogadore Terminal is petroleum bulk storage facility handling diesel fuel and gasoline. The facility is permitted to discharge treated storm water from two outfalls identified as 001 and 002. Outfall 001 discharges water from the east tank farm storage area containing two storage tanks and storm water from the manifold area. Water collected is routed to a "mud vault" prior to an oil/water separator and then to two small ponds located on the northern boundary of the facility just inside the fence. Collected storm water is usually pumped from the second pond unless storm water flow is too large. A valve for a gravity drain then can be opened to discharge the storm water by gravity.

Outfall 002 discharges water from the west tank farm storage areas. Water is collected in the dikes flowing by gravity to two ponds connected in series before discharging. This outfall is also valved to ensure that an accidental spill is contained on-site.

At the time of the inspection, there was no flow and no obvious visual problems were observed at the outfalls. The first pond had a slight oil sheen on the surface. I suggested that absorbent pads be used to remove it before it made it to the second pond and possibly to the outfall. A compliance check of our Surface Water Information Management System (SWIMS) database indicated the following numeric violation of your National Pollutant Discharge Elimination System (NPDES) permit for the time period of January 2011 thru March 2013.

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
002	00400	pH	1D Conc	6.5	6.25	10/1/2012

If you should have any questions concerning this letter, feel free to contact this writer at (330) 963-1136 or by e-mail at phil.rhodes@epa.ohio.gov.

Sincerely,

Philip P. Rhodes, P. E.
Environmental Specialist II
Division of Surface Water

PPR/cs
File/Industrial Permit/Compliance