



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

May 9, 2013

RE: HOLMES COUNTY  
CLARK TOWNSHIP  
CHARM COUNTRY VIEW INN  
OHIO EPA PERMIT NO. 3PR00397\*BD

Paul Miller, Owner  
Charm Country View Inn  
P.O. Box 100  
Charm, OH 44617

Dear Mr. Miller:

On April 11, 2013, an inspection was conducted at the Charm Country View Inn, located at 3334 State Route 557, Clark Township, Holmes County (facility). During the inspection, I was accompanied by Kraig Bucklew of the Holmes County Health Department. The purpose of the inspection was to evaluate the facility's compliance status with respect to the terms and conditions of the facility's National Pollutant Discharge Elimination System (NPDES) permit.

#### **Inspection Findings**

The following observations were made during the inspection:

1. The dosing system was tested and determined to be operation.
2. The clarifier was slightly grey in color and had sludge present on the surface of the wastewater. In addition, the clarifier weir had an accumulation of solids present. Maintenance of the clarifier must be performed.
3. The surface sand filters were clogged and require maintenance to be performed.
4. The middle baffle section of the chlorination/de-chlorination chamber was grey colored and requires maintenance.

#### **NPDES Permit Compliance Review**

A review of the electronic discharge self-monitoring reports (eDMRs) received by Ohio EPA for the period May 1, 2011 through May 1, 2013 indicates apparent noncompliance of the terms and conditions of your NPDES permit as identified below:

#### **Frequency Violations**

182 violations for Color, Severity (Reporting Code: 00083), 182 violations for Odor, Severity (Reporting Code: 01330), and 182 violations for Turbidity, Severity (Reporting Code: 01350) have occurred for Station 001.

CHARM COUNTRY VIEW INN  
MAY 9, 2013  
PAGE 2 OF 2

Please be aware that Color, Severity (Reporting Code: 00083), Odor, Severity (Reporting Code: 01330), and Turbidity, Severity (Reporting Code: 01350) must be monitored daily and reported to Ohio EPA utilizing eDMR.

The above frequency violations must be explained in writing as to why these required readings have not been performed, along with the corrective actions that will be implemented to ensure that they are not repeated.

Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1118 or via email at [chris.moody@epa.ohio.gov](mailto:chris.moody@epa.ohio.gov).

Sincerely,



Chris Moody  
Environmental Specialist II  
Division of Surface Water

CM/cs

cc: Kraig Bucklew, Holmes County Health Department