



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott F. Stelly, Director

May 17, 2013

Numan Babieh  
DOT District 5  
9600 Jacksontown Road  
Jacksontown, OH 43030

**Re: Storm Water Inspection at Canal Road Improvements / Licking County  
Permit #4GC03982\*AG**

Dear Mr. Babieh

This letter is written regarding the storm water inspection I conducted at the Canal Road / Interstate 70 Improvement project on May 2, 2013. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted:

**Sediment and Erosion Controls:**

- The ditch checks per the revised storm water pollution prevention plan are installed.
- Inlet protections along Interstate 70 are installed.
- Please maintain all sediment and erosion controls via your mandated self inspection reports every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm LIC 158 0 58 9-13-2012