



J. Ed. Brown, Governor
Mike DeWine, Lt. Governor
John P. DiStefano, Director

May 17, 2013

Scott Ford
Nissen Chemitec America
350 East High Street
London, OH 43140

Re: Nissen Chemitec America, Madison County

Dear Mr. Ford:

This letter is written regarding a storm water inspection I conducted on May 10, 2013, at Nissen Chemitec America, located at 350 East High Street, in London, Ohio. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following was observed at the site (also, please see attached pictures):

Sediment and Erosion Controls:

Please install additional erosion controls, such as silt fence or straw wattles around barren areas. Please maintain the erosion controls, there were several sections of silt fence that needed repaired.

Please be aware that the General Permit states that all barren areas including soil stockpiles which remain idle in excess of 21 days must be protected from erosion within 7 days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within 7 days. Most of the site was barren. Please stabilize the barren areas.

The weekly inspection log was not up-to-date. The storm water permit states that inspections should be conducted weekly or after a significant rain event. Storm water inspections had not been completed for the past month at the site.


If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

cc: Dublin Building Systems

GLS/nsm Nissan Chemitec, May 10, 2013



Taken at the...
Stables near...
Deer Creek Watershed
May 10, 2010
Photo by Greg Sanders



