



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

May 30, 2013

Jim Johnson
Storage One, LLC
P.O. Box 145
Carroll, OH 43112

Re: Storage One, LLC / Franklin County

Dear Mr. Johnson:

This letter is written regarding the storm water inspection I conducted on May 28, 2013, of the construction activities at Storage One, LLC located at 4975 Gender Road, in Columbus, Ohio. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following was observed or discussed at the site:

Sediment and Erosion Controls:

There did not appear to be any construction activity at the site. The site was stabilized and no erosion was leaving the site. Please be aware that if construction activities commence that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

GLS/nsm Storage One, LLC, May 28, 2013