



40 years and moving forward

John Kasich, Governor
Mark DeWine, Lt. Governor
Steve Stine, Director

May 20, 2013

Keith Coleman
The Pizzuti Companies
Two Mianova Place Suite 800
Columbus, OH, 43215.

**Re: Construction Storm Water Inspection at Axiom/ Licking County
Permit Number: 4GC04025 *AG**

Dear Mr. Keith Coleman:

This letter is written regarding a storm water inspection I conducted with Paul Hafner, and Sam Marotta of the Ohio EPA at Axiom located at 9005 Smith's Mill Road on May 22, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Appears that the majority of the construction is completed for the project; however there are barren areas that are not protected by erosion control.
- Please ensure that proper erosion measurements are taken to establish vegetation measured by a minimum density of 70 percent.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/hsm Axiom 5/22/2013