



John E. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Balig, Director

May 28, 2013

Mark Bush
Dollar General LLC
381 Summit Boulevard Suite 110
Birmingham, AL, 35243

Re: Construction Storm Water Inspection at Columbus (Parsons) Dollar General/ Franklin County Permit Number: 4GC04063 *AG

Dear Mark Bush:

This letter is written regarding a storm water inspection conducted by Paul Hafner, Brittany Turner, and Samuel Marotta of the Ohio EPA at Columbus (Parsons) Dollar General located at 1578 Parsons Avenue on May 20, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- This site appears to be void of any sediment controls. The General Permit states that all sediment controls must be implemented prior to initial grading of the site. Please implement these controls immediately to ensure compliance with the General Storm Water Permit.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.
- The entrance of the site must be stabilized to minimize off site vehicle tracking.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Columbus (Parsons) Dollar General 5-20-2013

Central District Office • 50 West Town Street • Suite 700 • P.O. Box 1049 • Columbus, OH 43216-1049
www.epa.ohio.gov • (614) 728-3778 • (614) 728-3898 (fax)