



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Erie County
EHOVE Career Center
Construction Storm Water
Facility ID No. 2GC03433*AG

May 31, 2013

Mr. Dave Jenkins
EHOVE Career Center
316 West Mason Road
Milan, Ohio 44846

Dear Mr. Jenkins:

On May 28, 2013, Zachary Titkemeier, Tom Wilkins, and I inspected the EHOVE Career Center located at 316 West Mason Road, Milan Township. The purpose of our visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity (Construction General Permit or CGP). The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

At the EHOVE Career Center site, no earthwork was occurring and no construction equipment was present. Zachary Titkemeier corresponded with you through e-mail on May 29, 2013. You indicated that the project had gone out for bids a week ago and bids were expected by June 13. The project includes building expansions and renovations to the existing EHOVE Career Center building.

When construction does commence, please remember the permit requirements for storm water management during construction, such as weekly self-inspections and the requirement to apply cover within seven days on bare soil in any areas that will sit idle for more than 14 days. Sediment controls must be installed within seven days of grubbing and before any grading. Also, sediment settling basins used during the project are required to have outlet structures that withdraw water from the surface.

If there are any questions, please contact me at 419-373-3009.

Sincerely,

Lynette Hablitzel, P.E.
Division of Surface Water
Storm Water Program

/jlm

ec: Crystal Dymond, Storm Water Program Coordinator, Erie Soil & Water Conservation District
Jack Farschman, P.E., P.S., Erie County Engineer
Tracking