

John E. Kasich, Governor
Betty Royler, Lt. Governor
Scott J. Jolly, Director

June 5, 2013

Tucker Bohm
Daimler Group
1533 Lake Shore Drive
Columbus, OH 43204

**Re: Construction Storm Water Inspection at Knightsbridge MOB / Franklin County
Permit Number: 4GC04000 *AG**

Dear Mr. Bohm:

This letter is written regarding a storm water inspection conducted by Sam Marotta and Paul Hafner, of the Ohio EPA at Knightsbridge MOB located at 4895 Olentangy River Road on May 31, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Please maintain silt fencing on site edges to ensure proper functioning conditions (See Figure 1).
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Knightsbridge MOB 5-31-13




Figure 1: Please maintain silt fencing to ensure proper function.