



Edwin R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott L. Nally, Director

June 5, 2013

David Gilmore
Meijer Inc.
2929 Walker Avenue Northwest
Grand Rapids, MI, 49544

**Re: Construction Storm Water Inspection at Meijer Store Number 235/ Union County
Permit Number: 4GC04041 *AG**

Dear Mr. Gilmore:

This letter is written regarding a storm water inspection conducted by Paul Hafner of the Ohio EPA at Meijer Store Number 235 located at Colemans Crossing Boulevard on May 30, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- During the inspection Mr. Hafner noted the construction of a sediment pond on the northeast corner of the site. The pond must be modified for sediment control with the installation of a sediment control outlet such as a skimmer within 10 days from receipt of this letter (See Figures 1, 2, and 3). Please ensure positive drainage to the pond prior to the storm sewer installation
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Post Construction Requirements: The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.

David Gilmore
Meijer Inc.
Page 2

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely

A handwritten signature in black ink, appearing to read "Harry Kallipolitis". The signature is written in a cursive style with a long horizontal stroke extending to the right.

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Meijer Store No 235 5-30-13





Figure 1 Sediment Pond not Complete





Figure 2 Sediment Pond Not Complete




Figure 3 Sediment Pond Not Complete