



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: **Notice of Violation**
Auglaize County
Waynesfield WWTP
Waynesfield WTP

June 7, 2013

Mr. Ronald Suter
Wastewater Operator
Village of Waynesfield
P.O. Box 476
Waynesfield, Ohio 45896

Dear Mr. Suter:

We are in receipt of your self-monitoring reports covering the months of January through March 2013 for the above referenced facilities. Our review indicates violations of the conditions of the above referenced National Pollutant Discharge Elimination System (NPDES) permits. The specific instances of non-compliance are enclosed on separate sheets.


Within 10 days of the date of this letter, please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General Conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code (ORC) Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. Information about Ohio EPA's Office of Compliance Assistance & Pollution Prevention can be found on Ohio EPA's Website at <http://epa.ohio.gov/ocapp> or by calling (614) 644 – 3469.

If there are any questions, please contact me at (419) 373 – 3022.

Sincerely,


Justin A. Williams
Environmental Specialist II
Division of Surface Water

/jlm
Enclosures
ec: NOV Tracking

Get New Data

Violations for Waynesfield WWT P - January - March 2013

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00022*KD	January 2013	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	3.2	7.63737	1/1/2013
2PB00022*KD	January 2013	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	4.9	12.7757	1/15/2013

Get New Data

Violation for Waynesfield WTP January - March 2013

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
21Y00003*DD	January 2013	001	00400	pH	1D Conc	6.5	6.4	1/16/2013