



John R. Kasich, Governor
Mike Taylor, Lt. Governor
Scott J. Malby, Director

June 6, 2013

Floyd E. Wicks
Rockmill Development Corp.
4920 E. Fifth Ave.
Columbus, OH 43219

Re: Misty Meadows / Fairfield County

Dear Mr. Wicks:

This letter is written regarding storm water inspection I conducted on June 4, 2013, of the construction activities at Misty Meadows, located in Fairfield County. I understand this site is currently covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the conditions set forth in the General Permit, the following items must be addressed:

Sediment and Erosion Controls:

There appeared to be one active site located at 1035 Sun Ridge Street, during the time of the inspection. The site had erosion controls in place but they needed to be maintained. Please inspect and maintain erosion controls weekly or after a significant rain event. Please see attached pictures.

Please be aware that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Storm Water Section
Division of Surface Water
Central District Office

Enclosure

c: Mike Young, Rockmill Development Corporation
James Pate, City of Lancaster
Chris Phelps, Maronda Homes

GS/nsm Misty Meadows, June 4, 2013

