



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Sandusky County
Fremont Reservoir – Phase 1
Construction Storm Water

June 12, 2013

Mr. Joe Flahiff
City of Fremont
323 South Front Street
Fremont, Ohio 43420

HM Miller Construction Company
1225 Waterloo Road
Mogadore, Ohio 44360

Dear Mr. Flahiff and HM Miller Construction Company:

On May 30, 2013, I conducted an inspection of the Fremont Reservoir - Phase 1, located on the southwest corner of South River Road and Greensburg Pike. The purpose of this inspection was to evaluate compliance of the site with your National Pollutant Discharge Elimination System (NPDES) permit for storm water associated with construction activity, Construction General Permit (CGP) Facility ID NO. 2GC02661*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

The CGP was issued to the City of Fremont on June 10, 2010. HM Miller Construction Company is Co-Permittee. Construction on this project is substantially complete with the exception of attaining a uniform perennial vegetative cover. Currently, there are numerous bare areas around the reservoir that have been mulched with straw. This permit cannot be terminated until final stabilization has been achieved on all portions of the site and all temporary erosion and sediment controls are removed (see part IV.B of the CGP). Until this project is properly terminated, all temporary control practices shall be maintained (see Part III.G.2.h of the CGP) and inspections and inspection logs are to be continued on all areas that have not reached final stabilization (see Part III.G.2.i of the CGP).

If you have any questions, you may contact me at (419) 373-3016 or by e-mail at patricia.tebbe@epa.ohio.gov.

Sincerely,

Patricia A. Tebbe, P.E.
Division of Surface Water

/jlm

pc: Sandusky SWCD

ec: Tracking