



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Ottawa County  
Bataan Elementary School  
Storm Water Construction  
Permit No. 2GC02792\*AG

June 12, 2013

Mr. Terry Clark  
Port Clinton City Schools  
431 Portage Drive  
Port Clinton, Ohio 43452

M. Campbell Contracting LLC  
3940 Eastern Road  
Doylestown, Ohio 44230

Dear Mr. Clark and M. Campbell Contracting:

On May 30, 2013, I conducted an inspection of the Bataan Elementary School located at 525 West Sixth Street in the City of Port Clinton, Ottawa County. The purpose of this visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity also known as the Construction General Permit (CGP). Observations made are under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

The CGP was issued to the Port Clinton City School District on January 20, 2011. M. Campbell Contracting is a co-permittee on this permit. Construction on this project is substantially complete with the exception of attaining a uniform perennial vegetative cover. Currently, there are numerous bare areas on the front lawn, some of which have been mulched with straw. This permit cannot be terminated until final stabilization has been achieved on all portions of the site and all temporary erosion and sediment controls are removed (see part IV.B of the CGP). Until this project is properly terminated, all temporary control practices shall be maintained (see Part III.G.2.h of the CGP) and inspections and inspection logs are to be continued on all areas that have not reached final stabilization (see Part III.G.2.i of the CGP).

Care should be taken to keep the straw covering all bare patches until there is a permanent vegetative cover. Any catch basins in the area should also have sediment controls in order to keep dirt from entering the catch basins.

If you have any questions, you may contact me at (419) 373-3016 or by e-mail at [patricia.tebbe@epa.ohio.gov](mailto:patricia.tebbe@epa.ohio.gov).

Sincerely,

Patricia A. Tebbe, P.E.  
Division of Surface Water

/jlm  
pc: Ottawa County SWCD  
ec: Tracking